



SYRACUSE UNIVERSITY HAVEN HALL



2015 RESIDENCE HALL FIRE SAFETY REPORT

Building Name: Haven Hall	Address: 400 Comstock Ave.
Building Size: 11 floors plus basement and penthouse, 6 exits	Building Capacity: 373

FIRE PROTECTION SYSTEMS

Sprinkler System: Wet system throughout building including 100% of student rooms; 3 pre-action dry systems cover the electrical vault and the elevator mechanical room.	
Fire Pump: 1,000 GPM Electric Flow Meter	Fire Alarm Control Panel: FCI/FC7200
Addressable Pull Stations: 37	Spk. Supervisory: 36
Photo-Electric Smoke Detectors: 269	Water Flow Switches: 26
Heat Detectors: 50	Roof Hatches: 0
Duct Detectors: 4	Fire Shutters/Louvers: 0
Alarm: Horns w/Visual - 25	Beam Detectors: 0
Fire Extinguishers: 52	Alarm System Type: Campus Tie
Ansul Systems: 4	Inspections Requirements: NFPA 72 (1 thru 7)

INSPECTION, TESTING, & MAINTENANCE

Evacuation Drills:	2/19/15	3/27/15	10/6/15	11/5/15
Smoke Detection Certification:	5/12/15			
NYS Office of Fire Prevention and Control Inspection: 10/16/15				

FIRE ALARMS

Date	Cause	Date	Cause
2/21/15	Dust	7/11/15	Unknown
10/6/15	Cooking	10/6/15	Electrical
11/8/15	Unknown	11/30/15	Unknown

2015 Fire Alarms

