



SYRACUSE UNIVERSITY SKYHALL 3



2015 RESIDENCE HALL FIRE SAFETY REPORT

Building Name: Skyhall 3	Address: 430 Lambreth Lane
Building Size: 3 floors plus basement, 3 exits	Building Capacity: 117

FIRE PROTECTION SYSTEMS

Sprinkler System: Wet system throughout building including 100% of student rooms.	
Fire Pump: 1,000 GPM Electric Flow Meter	Fire Alarm Control Panel: EST-3
Addressable Pull Stations: 13	Spk. Supervisory: 9
Photo-Electric Smoke Detectors: 36	Water Flow Switches: 4
Heat Detectors: 12	Roof Hatches: 3
Duct Detectors: 0	Fire Shutters/Louvers: 0
Alarm: Horns w/Visual – 91	Beam Detectors: 0
Fire Extinguishers: 10	Alarm System Type: Campus Tie
Ansul Systems: 0	Inspections Requirements: NFPA 72 (1 thru 7)

INSPECTION, TESTING, & MAINTENANCE

Evacuation Drills:	2/19/15	3/25/15	10/6/15	11/5/15
Smoke Detection Certification:	5/11/15			
NYS Office of Fire Prevention and Control Inspection: 9/21/15				

FIRE ALARMS

Date	Cause	Date	Cause
6/7/15	Contractor	8/29/15	Cooking
11/4/15	Cooking		

2015 Fire Alarms

