



# SYRACUSE UNIVERSITY BOOTH HALL



## 2015 RESIDENCE HALL FIRE SAFETY REPORT

<b>Building Name:</b> Booth Hall	<b>Address:</b> 505 Comstock Ave
<b>Building Size:</b> 9 floors plus basement, 4 exits	<b>Building Capacity:</b> 261

### FIRE PROTECTION SYSTEMS

Sprinkler System: <b>Wet system throughout building including 100% of student rooms; 2 pre-action dry systems cover the electrical vault and the elevator mechanical room</b>	
Fire Pump: 1,000 GPM Electric Flow Meter	Fire Alarm Control Panel: EST-3
Addressable Pull Stations: 27	Sprinkler Supervisory: 22
Photo-Electric Smoke Detectors: 158	Water Flow Switches: 18
Heat Detectors: 18	Roof Hatches: 0
Duct Detectors: 0	Fire Shutters/Louvers: 0
Alarm: Horns w/Visual: 70	Beam Detectors: 0
Fire Extinguishers: 33	Alarm System Type: Campus Tie
Ansul Systems: 0	Inspections Requirements: NFPA 72 (1 thru 7)

### INSPECTION, TESTING, & MAINTENANCE

Evacuation Drills:	2/24/15	3/24/15	10/7/15	11/5/15
Smoke Detection Certification:	6/14/15			
NYS Office of Fire Prevention and Control Inspection: 10/16/15				

### FIRE ALARMS

Date	Cause	Date	Cause
2/1/15	Steam	3/11/15	Cooking
3/26/15	Cooking	4/7/15	Unknown
4/23/15	Cooking	6/12/15	Cooking
6/25/15	Cooking	7/8/15	Cooking

7/21/15	Accidental	8/7/15	Cooking
8/29/15	Cooking	9/16/15	Cooking
10/1/15	Cooking	10/5/15	Unknown
10/24/15	Cooking	11/6/15	Accidental
11/13/15	Accidental		

