



SYRACUSE UNIVERSITY KIMMEL HALL



2015 RESIDENCE HALL FIRE SAFETY REPORT

| | |
|--|--|
| Building Name: Kimmel Hall | Address: 311 Waverly Ave. |
| Building Size: 4 floors, 4 exits | Building Capacity: 113 |
| FIRE PROTECTION SYSTEMS | |
| Sprinkler System: Wet system throughout building including 100% of student rooms; 1 pre-action dry system covers the electrical vault and the elevator mechanical room. | |
| Fire Pump: 1,000 GPM Electric Flow Meter | Fire Alarm Control Panel: FCI/FC7200 |
| Addressable Pull Stations: 18 | Spk. Supervisory: 18 |
| Photo-Electric Smoke Detectors: 61 | Water Flow Switches: 8 |
| Heat Detectors: 14 | Roof Hatches: 0 |
| Duct Detectors: 0 | Fire Shutters/Louvers: 2 |
| Alarm: Horns w/Visual -13 | Beam Detectors: 0 |
| Fire Extinguishers: 16 | Alarm System Type: Campus Tie |
| Ansul Systems: 8 | Inspections Requirements: NFPA 72 (1 thru 7) |

INSPECTION, TESTING, & MAINTENANCE

| | | | | |
|--|---------|---------|---------|---------|
| Evacuation Drills: | 2/24/15 | 3/24/15 | 10/7/15 | 11/5/15 |
| Smoke Detection Certification: | 5/11/15 | | | |
| NYS Office of Fire Prevention and Control Inspection: 10/14/15 | | | | |

FIRE ALARMS

| Date | Cause | Date | Cause |
|------|-------|------|-------|
|------|-------|------|-------|

| | | | |
|---------|------------|---------|------------|
| 5/11/15 | Sprinkler | 6/1/15 | Contractor |
| 6/5/15 | Unknown | 6/6/15 | Contractor |
| 6/10/15 | Unknown | 6/22/15 | Unknown |
| 7/7/15 | Electrical | | |

