



# SYRACUSE UNIVERSITY LAWRINSON HALL



## 2015 RESIDENCE HALL FIRE SAFETY REPORT

<b>Building Name:</b> Lawrinson Hall	<b>Address:</b> 303 Stadium Pl.
<b>Building Size:</b> 21 floors plus basement and sub-basement, 5 exits	<b>Building Capacity:</b> 552

## FIRE PROTECTION SYSTEMS

<b>Sprinkler System:</b> <span style="color: red;">Wet system throughout building including 100% of student rooms; 2 pre-actions dry systems cover the electrical vault and elevator mechanical room.</span>	
Fire Pump: 1,000 GPM Electric Flow Meter	Fire Alarm Control Panel: EST-3
Addressable Pull Stations: 53	Spk. Supervisory: 35
Photo-Electric Smoke Detectors: 118	Water Flow Switches: 32
Heat Detectors: 71	Roof Hatches: 3
Duct Detectors: 3	Fire Shutters/Louvers: 0
Alarm: Horns w/Visual – 232	Beam Detectors: 0
Fire Extinguishers: 48	Alarm System Type: Campus Tie
Ansul Systems: 0	Inspections Requirements: NFPA 72 (1 thru 7)

## INSPECTION, TESTING, & MAINTENANCE

Evacuation Drills:	2/23/15	3/30/15	10/5/15	11/4/15
Smoke Detection Certification:	5/14/15			
NYS Office of Fire Prevention and Control Inspection: 10/9/15				

## FIRE ALARMS

Date	Cause	Date	Cause
1/20/15	Accidental	2/9/15	Unknown
2/14/15	Cooking	2/27/15	Accidental
3/21/15	Cooking	4/11/15	Cooking
4/17/15	Cooking	4/18/15	Cooking
5/7/15	Unknown	7/22/15	Dust
9/5/15	Cooking	9/13/15	Cooking
9/14/15	Cooking	9/20/15	Malicious
10/1/15	Steam	10/6/15	Cooking
10/20/15	Cooking	11/5/15	Cooking
11/10/15	Cooking	11/21/15	Cooking
12/9/15	Cooking		

