



SYRACUSE UNIVERSITY LYONS HALL



2015 RESIDENCE HALL FIRE SAFETY REPORT

Building Name: Lyons Hall	Address: 401 Euclid Ave.
Building Size: 3 floors plus basement, 2 exits	Building Capacity: 38

FIRE PROTECTION SYSTEMS

Sprinkler System: Wet system throughout building including 100% of student rooms; 1 pre-action dry system covers the electrical vault and the elevator mechanical room.	
Fire Pump: 1,000 GPM Electric Flow Meter	Fire Alarm Control Panel: FCI
Addressable Pull Stations: 8	Spk. Supervisory: 1
Photo-Electric Smoke Detectors: 26	Water Flow Switches: 2
Heat Detectors: 2	Roof Hatches: 2
Duct Detectors: 0	Fire Shutters/Louvers: 0
Alarm: Bells w/Visual – 5, Strobes only – 2	Beam Detectors: 0
Fire Extinguishers: 5	Alarm System Type: Campus Tie
Ansul Systems: 0	Inspections Requirements: NFPA 72 (1 thru 7)

INSPECTION, TESTING, & MAINTENANCE

Evacuation Drills:	2/17/15	3/25/15	10/5/15	11/2/15
Smoke Detection Certification:	5/13/15			
NYS Office of Fire Prevention and Control Inspection: 9/28/15				

FIRE ALARMS

Date	Cause	Date	Cause
7/1/15	Electrical	7/23/15	Unknown
8/5/15	Contractor		

2015 Fire Alarms

