



SYRACUSE UNIVERSITY MARION HALL



2015 RESIDENCE HALL FIRE SAFETY REPORT

Building Name: Marion Hall	Address: 303 Waverly Ave.
Building Size: 3 floors plus basement, 6 exits	Building Capacity: 149

FIRE PROTECTION SYSTEMS

Sprinkler System: Wet system throughout building including 100% of student rooms.	
Fire Pump: 1,000 GPM Electric Flow Meter	Fire Alarm Control Panel: EST-3
Addressable Pull Stations: 11	Spk. Supervisory: 8
Photo-Electric Smoke Detectors: 48	Water Flow Switches: 6
Heat Detectors: 4	Roof Hatches: 0
Duct Detectors: 0	Fire Shutters/Louvers: 0
Alarm: Horns w/Visual – 14	Beam Detectors: 0
Fire Extinguishers: 15	Alarm System Type: Campus Tie
Ansul Systems: 0	Inspections Requirements: NFPA 72 (1 thru 7)

INSPECTION, TESTING, & MAINTENANCE

Evacuation Drills:	2/24/15	3/24/15	10/7/15	11/5/15
Smoke Detection Certification:	5/11/15			
NYS Office of Fire Prevention and Control Inspection: 10/14/15				

FIRE ALARMS

Date	Cause	Date	Cause
2/6/15	Malicious	5/14/15	Contractor
5/17/15	Accidental	5/23/15	Contractor
6/15/15	Contractor	7/3/15	Contractor

2015 Fire Alarms

