



# SYRACUSE UNIVERSITY SKYHALL 2



## 2015 RESIDENCE HALL FIRE SAFETY REPORT

<b>Building Name:</b> Skyhall 2	<b>Address:</b> 420 Lambreth Lane
<b>Building Size:</b> 3 floors plus basement, 3 exits	<b>Building Capacity:</b> 117

### FIRE PROTECTION SYSTEMS

<b>Sprinkler System:</b> Wet system throughout building including 100% of student rooms.	
<b>Fire Pump:</b> 1,000 GPM Electric Flow Meter	<b>Fire Alarm Control Panel:</b> EST-3
<b>Addressable Pull Stations:</b> 13	<b>Spk. Supervisory:</b> 9
<b>Photo-Electric Smoke Detectors:</b> 36	<b>Water Flow Switches:</b> 4
<b>Heat Detectors:</b> 12	<b>Roof Hatches:</b> 3
<b>Duct Detectors:</b> 0	<b>Fire Shutters/Louvers:</b> 0
<b>Alarm:</b> Horns w/Visual – 91	<b>Beam Detectors:</b> 0
<b>Fire Extinguishers:</b> 10	<b>Alarm System Type:</b> Campus Tie
<b>Ansul Systems:</b> 0	<b>Inspections Requirements:</b> NFPA 72 (1 thru 7)

### INSPECTION, TESTING, & MAINTENANCE

<b>Evacuation Drills:</b>	2/19/15	3/25/15	10/6/15	11/5/15
<b>Smoke Detection Certification:</b>	5/11/15			
<b>NYS Office of Fire Prevention and Control Inspection:</b> 9/21/15				

### FIRE ALARMS

Date	Cause	Date	Cause